

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1149Dated: 01/05/2025

It is certified that an inspection team headed by Rajendra Kumar
 (Name of officers with designation) from Sanitary & Food Inspector inspected the Lilawati
Convent School, Bilsoori, P.O. Sikandrabad, Distt.-Bulandshahr (Name & Address of the school) on
29.04.2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no.
363/20-7/08 dated 29.04.2025 of 15.04.2025 (PHED Lab)

certified that the Lilawati Convent School (Name of School) has safe drinking water facilities for the students
 and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school
 building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31 March 26.

Signature with Seal :

Name : Rajendra Kumar
 Designation : Sanitary & Food Inspector

Name & Address of the Office / Department:

Nagar Palika Parishad
Sikandrabad Bulandshahr (U.P.)

To

Lilawati Convent SchoolBilsoori, P.O. Sikandrabad, Distt.- Bulandshahr

(Name & Address of the Institution)

Manager
 MANAGER
 LILAWATI CONVENT SCHOOL
 BILSOORI (BULANDSHAHAR)

Shaily
 PRINCIPAL
 LILAWATI CONVENT SCHOOL
 BILSOORI (BULANDSHAHAR)



कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय
उ०प्र० जल निगम (ग्रामीण),
विकास भवन द्वितीय तल-336 बुलन्दशहर

पत्रांक:- 363

/ ५-7

/ ०४

दिनांक:- 18/04/2025

क्र०सं०	विकास खण्ड	ग्राम पंचायत का नाम	राजस्व ग्राम का नाम	स्थल का नाम	भौतिक परीक्षण				रासायनिक परीक्षण (पी० पी० एम०)						
					पी० एच०	टी० डी० एस०	टर्बिडिटी	रंग	क्लोराईड	सम्पूर्ण कठोरता	एल्कालिनिटी	आयरन	नाइट्रेट	फोस्फेट	जीवाणु
					6.5-8.5	500-2000	0-5		250-1000	200-600	200-600	0.3-1.0	0-45	1-1.5	0.01-0.05
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1	सिकंदराबाद	बिलसूरी	बिलसूरी	लीलावती कॉन्वेंट स्कूल	6.727	46.44	0.136	रंगहीन	44	280	84	10.00	30.0	0.5	0.0

Amits Sharma
Lab Chemist

MANAGER
LILAWATI CONVENT SCHOOL
BILSOORI (BULANDSHAHR)

JE (Lab)

PRINCIPAL
LILAWATI CONVENT SCHOOL
BILSOORI (BULANDSHAHR)

AE (Lab)